

AUSTRALIAN SLIP RESISTANCE STANDARDS BASED ON AS/NZS 4586

Source: CSIRO HB197 & Standards Australia AS/NZS 4586 and AS/NZS 4663

Minimum Pendulum or Ramp Recommendations :

LOCATION	PENDULUM	RAMP
Entry Foyers hotel, office, public buildings- wet	X	R10
Entry Foyers hotel, office, public buildings- dry	Z	R9
Shopping Centre- excluding food court	Z	R9
Shopping Centre- Food Court	X	R10
Internal Ramps, slopes (greater than 2 degrees)- dry	X	R10
Lift Lobbies above external entry level	Z	R9
Other separate shops inside shopping centres	Z	R9
Other shops with external entrances- entry area	X	R10
Fast food outlets, buffet food servery areas	X	R10
Hospitals and Aged Care facilities- dry areas	Z	R9
Hospitals and Aged Care facilities- ensuites	X	A or R10
Supermarket aisles except fresh food areas	Z	R9
Shop and Supermarket fresh fruit and vegetable areas	X	R10
Communal Changing Rooms	X	A
Swimming Pool Surrounds and Communal Shower Rooms	W	B
Toilet facilities in offices, hotels, shopping centres	X	R10
Undercover concourse areas of sports stadium	X	R10
Accessible internal stair nosings (dry)- handrails present	X	R10
Accessible internal stair nosings (wet)- handrails present	W	B or R11
